



NOTES:

1. CALL CITY WASTE WATER DIVISION (650-738-7472) 24 HOURS PRIOR TO SEWER PIPE INSTALLATION
2. CALL ENGINEERING (650-738-3767) 24 HOURS PRIOR TO PLACING BACKFILL
3. ALL TRENCHES AND/OR POTHoles SHALL BE RESTORED OR SAFELY COVERED BY 5:00 P.M. OF THE SAME DAY
4. SEWER TAP TRENCH SHALL BE 3' x 5' MAX. OR AS DIRECTED BY THE WASTE WATER DEPT.
5. SLURRY SEAL, IF REQUIRED, SHALL BE APPLIED APPROXIMATELY TWO WEEKS AFTER ALL TRENCHES AND POTHoles ARE RESTORED
6. CERTIFICATE OF COMPLIANCE MAY BE REQUIRED FOR THE ASPHALT, AND TACK COAT
7. SEE ALSO DETAILS 300A AND 300B

TRENCH WIDTH

CONDUIT SIZE:	3" OR LESS	4" TO 18"	OVER 18"
MIN. TRENCH WIDTH	6"	O.D. + 24"	O.D. + 36"

CITY OF  
PACIFICA

DEPARTMENT OF PUBLIC WORKS  
ENGINEERING DIVISION

STANDARD  
PAVED STREETS  
TRENCH DETAIL

AUG  
2014

DWG. NO.  
301A

REV	DATE	BY:
-----	------	-----